

**Corrigendum - I on Tender notification No. Letter No. Dr NTRVST/HR/590/2017: Date - 24.05.2017**

Sl.No	RFP document reference(s) )Section number/page)	Original Clause	Clause add/Delete/Modify	Amended Clause
	Page Number 4, Section 1-->Tender Notice --> 1 Schedule to Tender -->S.No 9	Nil	Addition	For Queries on UPS RFP: General Manager-PMU, Ph.No. 8333816775/8333817452 e-mail: ap_pmu@ntrvaidyaseva.ap.gov.in
2	Page no.10, Section IV, Sl.No 4	Batteries	Addition	Type of Batteries - SMF
3	Page no.11, Section IV, Sl.No 8	Isolation Transformer	Delete	Getting UPS full report, so Isolation Transformer test report not required due to it is a part of UPS
4	Page no.14, Section IV, Sl.No 18	Battery Circuit Breaker	Delete	Getting UPS full report, so Isolation Transformer test report not required due to it is a part of UPS
5	Page no.14, Section IV, Sl.No 19	Other Protections -->point No.5 (It should have Intelligent Battery Management system)	Delete	-
6	Page no.29, Price Bid form-->Sl.No 1	2x60 KVA online UPS with DSP control based ON-LINE Double Conversion Technology, Three phase input and Three phase output, IGBT with PFC control technology, Isolation transformer	Modify	2x60 KVA online UPS with 32bit DSP control based ON-LINE Double Conversion Technology, Three phase input and Three phase output, IGBT rectifier and IGBT inverter, Inbuilt Isolation transformer
7	Page no.29, Price Bid form-->Sl.No 2	Battery bank for 60 Min back up along with interconnecting cables, cable from UPS to Battery Bank with battery stand with 48 months warranty and TWO years maintenance	Modify	Battery bank for 60 Min back up along with interconnecting cables, cable from UPS to Battery Bank with battery stand with 24 months warranty and Three years comprehensive maintenance